



APPROVED

Certificate of Compliance

This certificate is issued for the following: Indicating Valves, Butterfly or Ball Type

Prepared for:

ARGCO
2610 COMMERCE WAY
VISTA, CA 92081 USA

Model Number	Product Type	Nominal Pipe Size, in. (mm)	Rated Working Pressure, psi (kPa)	Remarks
ARG-BB-T175	Butterfly Valve, Threaded Ends	1, 1 1/4, 1 1/2, 2, 2 1/2 (25, 32, 40, 50, 65)	175 (1205)	a, b
ARG-BB-G175	Butterfly Valve, Grooved Ends	2, 2 1/2 (50, 65)	175 (1205)	a, b
ARG-BFLY-G175	Butterfly Valve, Grooved Ends	2 1/2, 3, 4, 6, 8 (65, 80, 100, 150, 200)	175 (1205)	a, c, d
ARG-BFLY-W175	Butterfly Valve, Wafer Body	2 1/2, 3, 4, 6, 8 (65, 80, 100, 150, 200)	175 (1205)	a, c, d
ARG-BFLY-G300	Butterfly Valve, Grooved Ends	2-1/2, 3, 4, 6, 8 (65, 80, 100, 150, 200)	300 (2070)	a, c, d
ARG-BFLY-W300	Butterfly Valve, Wafer Style	2-1/2, 3, 4, 6, 8 (65, 80, 100, 150, 200)	300 (2070)	a, c, d

Remarks:

- a. Available with dual supervisory switches.
- b. FM Approved for above ground, indoor and outdoor use only.
- c. FM Approved for aboveground installations only.
- d. FM Approved for indoor and outdoor use.

FM Approvals Class: 1112

Approval Identification: 3048705

Approval Granted: July 26, 2013

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

Richard B. Dunne
Group Manager –Fire Protection Group
FM Approvals
1151 Boston-Providence Turnpike
Norwood, Massachusetts 02062 USA



Member of the FM Global Group



APPROVED

Certificate of Compliance

This certificate is issued for the following:

SINGLE CHECK VALVE, SWING CHECK VALVE

MODEL ARG-CH-300 IN SIZES 2, 2-1/2, 3, 4, 6, 8 in.

Prepared for:

ARGCO

2610 COMMERCE WAY

VISTA, CA 92081 USA

FM Approvals Class: 1210

Approval Identification: 3048705

Approval Granted: July 26, 2013

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

Richard B. Dunne
Group Manager –Fire Protection Group
FM Approvals
1151 Boston-Providence Turnpike
Norwood, Massachusetts 02062 USA



Member of the FM Global Group