ta shee С



Model 010 SWAY BRACE PIPE ATTACHMENT



FUNCTION:

Designed for bracing pipe against sway and seismic disturbance. The pipe attachment component of a sway brace system used in conjunction with a structura lattachment fitting and joined together wth a bracing pipe element forming a completeswaybraceassembly.

Sway brace assemblies are intended to be installed in accordance with NFPA 13 and the manufacturer's installation instructions.

SIZE:

Pipe size 1" thru 6" Schedule 10 thru 40 IP. Pipe size used for bracing 1" and 1-1/4" Schedule 40 IP. FINISH:Electro-galvanized

APPROVED

MATERIAL: Low Carbon Steel

NSTALLATION:

Place over the pipe to be braced, adjust brace angle, and insert bracing pipe through opening leaving a minimum of 1" extending from attachment.


Brace pipe can be installed on top or bottom of pipe to be braced.

Tighten nuts down evenly until hex head breaks off.

APPROVALS: Underwriters Laboratories listed for US and Canada

Listed for use with NFPA and PHD sway brace components only

Pipe Size	Brace Size	Maximum Design Load SCH10 Pipe	
1	1 & 1 1/4	655	655
1 1/4	1&11/4	655	655
1 1/2	1 & 1 1/4	655	655
2	1 & 1 1/4	655	655
2 1/2	1 & 1 1/4	655	655
3	1 & 1 1/4	655	655
4	1 & 1 1/4	N/A	655
6	1 1/4	1265	1265



CROSS REFERENCE: Erico: CSBQIK Afcon: Model E Tolco: 1000

The information contained herein is produced in good faith and is believed to be reliable but is for guidance only. ARGCO and its agents cannot assume liability or responsibility for results obtained in the use of its product by persons whose methods are outside or beyond our control. It is the user's responsibility to determine the suitability of any of the products, methods of use, or preparation prior to use, mentioned in our literature. It is the user's responsibility to observe and adapt such precautions as may be advisable for the protection of personnel and property in the handling and use of any of our products.

> FOR MORE INFORMATION CALL ARGCO AT 1-800-854-1015 **OR LOG ONTO WWW.ARGCO.COM**